Energy performance certificate (EPC)

Guidepost Inn
Makepeace Terrace
GATESHEAD
NE9 7RR

Makepeace Terrace
Certificate
number:

15 November 2027

Certificate
0450-0933-8189-33997096


Property type	C1 Hotels
Total floor area	422 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is E.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

37 B

If typical of the existing stock

107 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	240.6
Primary energy use (kWh/m2 per year)	1397

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/9990-5917-0483-8430-9030)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ron Clayton
Telephone	0203 397 8220
Email	ronclayton@sky.com

Contacting the accreditation scheme
If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Quidos Limited
QUID205856
01225 667 570
info@quidos.co.uk
Information not provided by the user
Information not provided by the user
The assessor is not related to the owner of the
property.
14 November 2017
16 November 2017

Energy performance certificate (EPC) recommendation report

Guidepost Inn Makepeace Terrace GATESHEAD NE9 7RR Report number 9990-5917-0483-8430-9030

Valid until **15 November 2027**

Energy rating and EPC

This property's energy rating is E.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Install more efficient water heater.	High
Consider replacing HWS with point of use system.	High
Consider replacing heating boiler plant with high efficiency type.	High
Add optimum start/stop to the heating system.	Medium
Some walls have uninsulated cavities - introduce cavity wall insulation.	High
Some windows have high U-values - consider installing secondary glazing.	High
Add weather compensation controls to heating system.	Medium
Some loft spaces are poorly insulated - install/improve insulation.	High
Consider replacing heating boiler plant with a condensing type.	High
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	High
Changes that may pay for themselves within 3 to 7 years	
Recommendation	Potential impact on carbon emissions
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	High
Changes that may pay for themselves in over 7 years	
Recommendation	Potential impact on

Recommendation	Potential impact on carbon emissions	
Roof is poorly insulated. Install or improve insulation of roof.	High	
Consider installing building mounted wind turbine(s).	Low	
Consider installing solar water heating.	Low	
Consider installing PV.	Low	

Additional recommendations

Recommendation Potential impact on carbon emissions

Insert Recommendation here

Low

Property and report details

Report issued on	16 November 2017
Total useful floor area	422 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	CLG, iSBEM, v5.3.a, SBEM, v5.3.a.0

Assessor's details

Accreditation scheme	Quidos Limited
Assessor's declaration	The assessor is not related to the owner of the property.
Assessor ID	QUID205856
Employer's address	Information not provided by the user
Employer's name	Information not provided by the user
Email	ronclayton@sky.com
Telephone	0203 397 8220
Assessor's name	Ron Clayton