

Energy performance certificate (EPC)

1 Moorside Road
Moorside
Sunderland
SR3 2SW

Energy rating

B

Valid until:

5 April 2033

Certificate
number:

7245-9738-8145-0786-
0872

Property type

Restaurants and Cafes/Drinking
Establishments/Takeaways

Total floor area

420 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.

Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.



How this property compares to others

Properties similar to this one could have ratings:

If newly built

21 A

If typical of the existing stock

83 D

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	54.19
Primary energy use (kWh/m ² per year)	424

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7889-8117-5018-5525-8104\)](/energy-certificate/7889-8117-5018-5525-8104).

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Lee Jacobson
Telephone	01642 424555
Email	surveys@energess.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/017786
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Employer	Energess COMMERCIAL
Employer address	Suite 29, Durham Tees Valley Business Centre, Orde Wingate Way, STOCKTON ON TEES, TS19 0GD
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	15 February 2023
Date of certificate	6 April 2023

Energy performance certificate (EPC) recommendation report

1 Moorside Road
Moorside
Sunderland
SR3 2SW

Report number
7889-8117-5018-5525-8104

Valid until
5 April 2033

Energy rating and EPC

This property's energy rating is B.

For more information on the property's energy performance, see the EPC for this property.

Recommendations

Changes that may pay for themselves within 3 years

Recommendation	Potential impact on carbon emissions
Add time control to heating system.	Medium
Add optimum start/stop to the heating system.	Medium
Some windows have high U-values - consider installing secondary glazing.	Medium
Add local temperature control to the heating system.	Medium
Add weather compensation controls to heating system.	Medium
Add local time control to heating system.	Medium
Consider switching from gas to biomass.	High
Carry out a pressure test, identify and treat identified air leakage. Enter result in EPC calculation.	Medium

Changes that may pay for themselves within 3 to 7 years

Recommendation	Potential impact on carbon emissions
Some glazing is poorly insulated. Replace/improve glazing and/or frames.	Medium
Consider installing an air source heat pump.	Medium
Consider installing a ground source heat pump.	Medium

Changes that may pay for themselves in over 7 years

Recommendation	Potential impact on carbon emissions
Consider installing building mounted wind turbine(s).	Low
Consider installing solar water heating.	Low
Consider installing PV.	Low

Property and report details

Report issued on	6 April 2023
Total useful floor area	420 square metres
Building environment	Heating and Natural Ventilation
Calculation tool	G-ISBEM Ltd, G-ISBEM, v25.3, SBEM, v6.1.e.0

Assessor's details

Assessor's name	Lee Jacobson
Telephone	01642 424555
Email	surveys@energess.co.uk
Employer's name	Energess COMMERCIAL
Employer's address	Suite 29, Durham Tees Valley Business Centre, Orde Wingate Way, STOCKTON ON TEES, TS19 0GD
Assessor ID	EES/017786
Assessor's declaration	The assessor is not related to the owner of the property.
Accreditation scheme	Elmhurst Energy Systems Ltd
